

# AMCA International Support Slides for Framework Document Public Hearing

Contact: Michael Ivanovich
Director of Strategic Energy Initiatives
AMCA International
mivanovich@amca.org
February 21, 2013

Note: These slides present draft, work-in-progress information and positions of AMCA, which may change when written comments are submitted.

### **Equipment Classes**

If forward curved fans were included in an Equipment Class of "Centrifugal – Clean air housed", they will be eliminated as the minimum efficiency metric is raised.

Forward curved fans are an excellent solution for ducted fan applications with low pressures – resulting in low first cost & energy, compact size and low sound.

Typical applications of forward curved fans in commercial ventilation are bathroom exhaust fans, return and exhaust fans in air handling units and general exhaust fans.



**Forward Curved** 



**Centrifugal Airfoil** 

## **Equipment Classes**

#### Low-pressure applications without outlet duct

35,000 CFM at 0.25" static pressure

Fan Type	Rotor	<u>Diameter</u>	<u>BHP</u>	<u>FEG</u>	Cost	<u>Weight</u>
Roof Prop Fan	Axial	54"	6.64	57	1	1,000 lbs
Utility Fan	Centr. AF	49"	10.35	85	2.43 X	2,000 lbs



Roof Propeller Fan



### **Equipment Classes**


#### AMCA-proposed Equipment Classes

- 1. Vane Axial
- 2. Panel and Tube Axial
- 3. Housed Centr. Backward Inclined
- 4. Housed Centr. Forward Curved
- 5. Housed Centr. Radial Bladed
- 6. Unhoused Centrifugal

- 7. Induced Flow Fans
- 8. Centrifugal Inline & Mixed Flow
- 9. Centrifugal Power Roof Ventilators
- 10. Axial Power Roof Ventilators
- 11. Circulation Fans Exempt
- 12. Air Curtains (including cross flow)
  - Exempt

Note: Centr. = Centrifugal

# **Efficiency Metrics**





U.S. Dept. of Energy development of fan-efficiency regulations. Estimated date of start of enforcement is 2020, but could be as early as 2018.

#### Legend

**CCP:** Code change proposal (for I-codes). Deadline in January, two years before publication year.

**CMP:** Continuous maintenance proposal for ASHRAE. Can be submitted at any time.

CP: Change proposal for IAPMO Green

Supplement to Uniform Mechanical Code and Uniform Plumbing Code. Changes accepted following publication of most-recent version.

IAPMO: International Assoc. of Plumbing and Mechanical Officials

IECC: International Energy Conservation Code,

published by ICC

**IgCC:** International Green Construction Code, published by ICC

**2015:** Year that fan efficiency requirements likely to be in all national model codes and standards for energy efficiency and green construction.

#### **Product Selection**



Operating Performance 80,000 CFM

3.0" SP


<u>e</u> Data from Cookware v6.0 (Loren Cook Company)

Model	FEG	Total Efficiency	Operating Power (HP)	Budget Price	Operating Cost/Yr	Weight
365CADWDI	85	56%	114	\$21,100	\$37,797	2330
402CADWDI	85	62%	90	\$16,100	\$29,939	2850
445CADWDI	85	68%	74	\$16,900	\$24,402	3570
490CADWDI	85	77%	60	\$17,600	\$19,926	4170
540CADWDI	85	78 <b>%</b>	56	\$20,300	\$18,401	5200
600CADWDI	85	81%	51	\$23,800	\$16,976	6310
660CADWDI	85	81%	50	\$27.400	\$16.478	7490

Operating cost based on 16 hrs/day, 250 days/year and \$0.10/kw-hr


- All sizes are FEG85 (represents the energy efficiency potential)
- Actual efficiency at the operating point varies greatly (larger sizes are operating close to peak efficiency)
- This illustrates the impact proper selection has on energy efficiency






- Fans have a peak operating efficiency at one point
- The dome-shaped efficiency curve illustrates the great range of fan efficiency





 The bold red line indicates the selection range for efficient and stable fan selection













# Each fan type is available in many model sizes



















# Each model size has numerous motor & drive variations

#### Many motor sizes



20" Impeller



3/4 hp



1 hp



1 1/2 hp



2 hp



3 hp



5 hp



7 1/2 hp

#### Many motor enclosures

- Open drip proof
- TE fan cooled
- TE air over
- Explosion resistant
- Two speed

Standard and Premium Efficiency motors



Many belt and pulley combinations for each modesize



# Fan-Motor-Drive Permutations – Conservative Estimate

#### **Direct Drive Fans**

Fan models 400 (40 fan types; average 10 sizes per type)

Motors per model x 5 (ranges from 1 to 50 motors per model)

**Total Variations** 2,000

#### **Belt Drive Fans**

**Fan models** 960 (60 fan types; average 16 sizes per type)

Motors per model x 30 (6 motor sizes and 5 enclosure types)

**Drives per motor**  $\underline{x}$  **7** (3 for adjustable; 20 for fixed)

**Total Variations 201,600** 

Variations due to motor manufacturer and drive manufacturer differences?